

# Compliance Statement

No. 2019-212

## Data communication cable, Category 6A

### Company

Fumo Telecommunication UG (haftungsbeschränkt)  
4<sup>th</sup> floor, Gothardstrasse 11  
10178 Berlin  
Germany

### Product description

Unscreened cable (U/UTP) characterised up to 500 MHz  
Horizontal floor wiring cable, 100 Ω  
4 twisted pairs  
Flame retardant, PVC jacket

### Product identification

Part no. GLCAU6AP

### Generic cabling and cabling components standards - Category 6A cable requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 61156-5:2012 (Ed. 2.1)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-11-1:2012
- TIA-568.2-D:2018

### Standards for flame retardancy

- IEC 60332-1-1:2015 (Ed. 1.1)
- IEC 60332-1-2:2015 (Ed. 1.1)

### Technical report

T924573, DANAK-19/20048

### EC Cabling product ID


6861

### CS valid until

15 March 2020

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 15 March 2019



Lars Lindskov Pedersen  
Test Manager



Dennis Andersen  
Head of Department

